



Ref No. : MPL/11022019

DATED.:11.02.2019

TEST CERTIFICATE

Date & time of collection: NA
Collected by: **TILAK RAJ**
Source:- R.O. WATER

Date of receipt : 11/02/2019
Date of analysis : 11/02/2019 to 14/02/2019

ISSUED TO:
LADY FLORENCE PUBLIC SCHOOL, VILL. BEGUM PUR, KHATOLA
(GURGAON)

Lab No.:11022019/W/2019
Your Ref No.: NIL

TEST RESULTS (as per IS : 10500-1991)

<u>S.No.</u>	<u>PARAMETER</u>	<u>RESULTS</u>	<u>IS: Requirement</u>	<u>RELAXATIONS in absence</u>
			<u>Desirable Limits</u>	<u>of Alternate Source</u>

PHYSICAL EXAMINATION

01.	Colour	Unobjectionable	5 H.U. (Max)	25
02.	Odour	Unobjectionable	Unobjectionable	Unobjectionable
03.	pH	7.0	6.5-8.5	No relaxation
04.	Dissolved Solids (mg/l)	186 mg/l	500	2000

CHEMICAL EXAMINATION (mg/l)

01.	Total hardness (as CaCO ₃)	310 mg/l	300Max	600
02.	Total Alkalinity (as CaCO ₃)	28 mg/l	200Max	600
03.	Chlorides (as Cl)	10 mg/l	250Max	1000
04.	Dissolved Iron (as Fe)	*BDL	0.3Max	1.0
05.	Fluoride (as F)	*BDL	1.0Max	1.5
06.	Residual Chlorine (as Cl ₂)	*BDL	0.2Max	0.5

* B.D.L.: - Below detectable Limits

Chemist/Microbiologist

Lab Incharge



AN ISO 9001:2008
CERTIFIED LABORATORY

It is presumed that the test(s) performed are on the specimen(s) sample(s) belonging to the patient named or identified and the verification of the particulars have been carried out by the patient or his/her representative at the point of generation of the said specimen(s) or sample(s).



Ref No. : MPL/11022019

DATED.:11.02.2019

TEST CERTIFICATE

Date & time of collection: NA
Collected by: **TILAK RAJ**
Source:- R.O. WATER

Date of receipt : 11/02/2019
Date of analysis : 11/02/2019 to 14/02/2019

ISSUED TO:
LADY FLORENCE PUBLIC SCHOOL, VILL. BEGUM PUR KHATOLA
(GURGAON)

Lab No.:11022019/W/2019
Your Ref No.: NIL

TEST RESULTS (as per IS : 10500-1991)

BACTERIOLOGICAL EXAMINATION

TEST REPORT RESULT

**MAX. ALLOWED AS PER
WHO Guideline IS-10500:1991**

Most Probable Number of Coliforms (NIL)	2	10
Organisms per 100ml of water		

OPINION:- The bacteriological analysis of the sample indicates that it is fit for human consumption as per IS Specifications.

* B.D.L.: - Below detectable Limits

Chemist/Microbiologist

Lab Incharge



**AN ISO 9001:2008
CERTIFIED LABORATORY**

It is presumed that the test(s) performed are on the specimen(s) sample(s) belonging to the patient referred or identified and the verification of the particulars have been carried out by the patient or his/her representative at the point of generation of the said specimen(s) or sample(s).